

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO ITB #21-0135-7

FOR: Southbridge Golf Course Storm Pipe Replacement Project

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question:** Who will be responsible for repairing any damage to the irrigation system? If it is the contractors responsibility what will be the method of measurement and payment?
Response: Any damage to the irrigation system shall be repaired by the contractor as it occurs. Payment shall be a lump sum based on time and materials for each occurrence as an item under the Field Condition Allowance.
2. **Question:** Could you please provide the desired variety for the replacement sod?
Response: The Golf Club has confirmed that the grass on the holes to be impacted is Bermuda.
3. **Question:** Will the pipe require 57 stone bedding to the haunch of the pipe?
Response: Yes, the pipe shall be bedded up to the haunch with stone. The price of the bedding is to be included in the price per linear foot bid for pipe.

**THE BID OPENING DATE REMAINS 2:00PM,
DECEMBER 16, 2021.**

BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

December 8, 2021

DATE



MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY