

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 1 TO BID NO. 21-0138-3

FOR: ANNUAL CONTRACT FOR HVAC MAINTENANCE SERVICES AT THE J. TOM COLEMAN JUDICIAL COURTHOUSE

=====

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHAGES:

1. **CHANGE:** Section 4.5.5 C, shall now read:

Air Handling Units Air grills, (cleaning), registers, (cleaning), air filters, and check coils for bacteria buildup. Air filters "MUST" be rated at Merv 13.

2. **CHANGE:** Section 4.9 Item 14

Building Automated Control System (Delta Controls)

- Contractor will be required to work BAS Contractor insuring that All Equipment is properly calibrated with BAS System

3. **ADDITION:** Section 4.9 Equipment List

- | | |
|---------|---|
| Item 19 | Domestic Water Heater
Manufacture: Glashield
Model: 36G300A-E
Voltage: 480 volts 3 phase @ 43 amps
Storage Capacity: 300 gal. |
| Item 20 | Hot Water Mixing Valve
Manufacture: Leonard Thermostatic
Model : TASG97-10B |
| Item 21 | Circulating Pumps
Manufacture: Marathon
Model: HQM-56C17D5537EP
Voltage: 115/208-230 ¾ Hp |

THE BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

12-6-21
DATE



MARGARET H. JOYNER, PURCHASING DIRECTOR
CHATHAM COUNTY, GEORGIA