

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 3 TO 21-0097-4

FOR: WILLOW LAKES DRAINAGE IMPROVEMENTS

PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

Responses to Additional Questions Received:

1. Q) Addendum 2 included an alternate for using 48" HDPE pipe in lieu of RCP. What thickness is required, type HP or N-12 ?

A) ADS N-12 or equivalent.


2. Q) Is it to be 'water-tight' or not; single or double gasket joints ?

A) Water-tight. Single gasket. The joints shall be double wrapped with filter fabric.

**BID OPENING REMAINS: 2PM, WEDNESDAY,
SEPTEMBER 15, 2021**

THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.

9/9/21
DATE


ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY