

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO BID# 21-0092-5

**FOR: ANNUAL CONTRACT FOR CHILLER AND COOLING TOWER  
PREVENTATIVE MAINTENANCE AND REPAIR SERVICES AT THE CHATHAM  
COUNTY DETENTION CENTER**

---

---

**PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR  
CHANGES:**

1. **Question:** Is chemical treatment required?  
**Answer:** No, the County has a separate contract for this.
2. **Question:** Eddy Current test on evaporator and condenser tubes?  
**Answer:** Yes, both are required.

---

---

**BID DUE DATE WILL REMAIN 2:00PM, AUGUST  
3, 2021**

---

---

**BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.**

---

---

July 30, 2021

DATE

  
MARGARET H. JOYNER  
PURCHASING DIRECTOR  
CHATHAM COUNTY