

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 1 TO 21-0101-4

**FOR: CHATHAM COUNTY RECORDS CENTER DRIVEWAY
IMPROVEMENTS**


**PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR
CHANGES:**

1. See attached sheet for Responses to Questions Received and Substitute Requests.
(1 page)

**BID OPENING REMAINS:
2PM, THURSDAY, SEPTEMBER 9, 2021**

**THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY
CHANGES AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

8/30/21
DATE


ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY

Questions Received:

1. Q) Is Parkers aware of this project and acceptable to their entrance closures ?
A) Improvements are being coordinated with Parkers.
2. Q) The separate entrance to the dumpsters will also be blocked. What is the dumpster schedule at this Parkers Store ? Can they keep it closed it for 14 days ? Or can they relocate the dumpsters during this project ? The County is coordinating the repairs with
A) Parkers and will attempt to have the dumpsters temporarily relocated.
3. Q) Is Burger King and the local franchisee aware of this project and acceptable to their entrance being closed ?
A) The improvements have been coordinated with Burger King. They have been made aware the driveways will need to be closed to facilitate construction of the improvements.
4. Q) The plans indicate the concrete drive to contain fibermesh. We find no rebar. Please confirm no rebar.
A) No rebar.
5. Q) Are the joints in the new concrete to be doweled?
A) No doweled joints.