

CHATHAM COUNTY PURCHASING DEPARTMENT

ADDENDUM NO. 1 TO ITB #22-0032-7

FOR: Remove/Replace Damaged Storm Pipes at Various Locations on Three Canals

PLEASE SEE THE FOLLOWING ADDITIONS, CLARIFICATIONS AND/OR CHANGES:

1. **Question:** Does the last sentence of Section 4.2, paragraph B (pdf. page 23) denote the pipes have to be backfilled up sufficiently to bring the crossing finish grade up to existing canal road?
Response: Yes, the last sentence of Section 4.2, paragraph B (pdf page 23) indicates that the pipes have to be backfilled up to bring the finish grade up to existing canal road grade.
2. **Question:** Is any stone required to be installed for the road crossing surface once the culvert r/r is completed.
Response: No, clean fill dirt and proper erosion control (seed and thatch) is required for the road crossing surface once the culvert pipes are removed and replaced.

**THE BID OPENING DATE REMAINS 2:00PM,
APRIL 21, 2022.**

BIDDER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES.

April 12, 2022

DATE


MARGARET H. JOYNER
PURCHASING DIRECTOR
CHATHAM COUNTY