

CHATHAM COUNTY PURCHASING & CONTRACTING DEPARTMENT

ADDENDUM NO. 2 TO 21-0149-4

**FOR: 2021 RESURFACING / WILMINGTON ISLAND ROAD SAFETY
ENHANCEMENTS**

**PLEASE SEE THE FOLLOWING FOR ADDITIONS, CLARIFICATIONS AND/OR
CHANGES:**

RESPONSE TO QUESTION RECEIVED :


Q) On Aimar Ave, the bid documents say to “Build driveway aprons at 30 dirt drives, 17 concrete drives, and 5 asphalt drives.” How should we tie into the existing concrete & asphalt drives?

A) This would be an overlay and tie down. Please refer to Aimar Avenue in the Turn Out Listing, “pave existing asphalt and concrete driveways 1’ to 5’ back from edge of pavement to ensure a smooth transition.”

**BID OPENING REMAINS : 2PM, TUESDAY,
FEBRUARY 8, 2022**

**THE PROPOSER IS RESPONSIBLE FOR MAKING THE NECESSARY CHANGES
AND MUST ACKNOWLEDGE RECEIPT OF ADDENDUM.**

2/1/22
DATE



ROBERT E. MARSHALL
SENIOR PROCUREMENT SPECIALIST
CHATHAM COUNTY